



**Request for Quotation (RFQ)
Professional Services – Sanitary and Storm Sewer Pipeline Study with CCTV for the
Fernández Juncos Avenue and Connectors
Economic Development Investment Portfolio for Growth Program (IPG)
Community Development Block Grant – Disaster Recovery (CDBG-DR)
Puerto Rico Convention Center District Authority
CDBG-DR-IPG-PRCCDA-2026-02**

ADDENDUM NO. 2
RESPONSES AND CLARIFICATIONS

On **February 27, 2026**, the Puerto Rico Convention Center District Authority ("PRCCDA") issued a "Request for Quotations" for the acquisition of **Professional Services – Sanitary and Storm Sewer Pipeline Study with CCTV for the Fernández Juncos Avenue and Connectors, Procurement No. CDBG-DR-IPG-PRCCDA-2026-02** under the CRBG-DR, IPG Program.

On March 12, 2026, a First Addendum was issued to extend the period of submission of quotes to **March 19, 2026, by 11:59 pm (AST)**. The term for submission of Accordingly, inquiries or requests for clarification regarding the RFQ were to be submitted no later than March 16, 2026.

Notice is given of this Second Addendum to the RFQ to clarify and respond the following inquiries, timely brought to the attention of the PRCCDA:

1. **Request for clarification:**

"I was wondering if you could extend the submittal date by two weeks."

Response:

On March 12, 2026, the PRCCDA issued Addendum No.1 extending the submission to March 19, 2026, 11:59 pm (AST). No other extensions will be granted.

2. **Request for clarification:**

"I see the proposal doesn't request a bi-pass for the lines. We understand that maybe the Storm Water one might be easier to coordinate as it will be dependant on the weather. But the sanitary lines may require it."

Response:

The RFQ does not specifically require a bi-pass system for the pipeline inspections. However, proposers should include in their methodology any operational

measures they consider necessary to safely and effectively perform the CCTV inspection of both stormwater and sanitary sewer lines. The means and methods is to be determined by the professional services provider. Please refer to the RFQ Scope of Services, Section 4, Methodology.

3. Request for clarification:

“Regarding the cleaning, other work we are doing with sanitary lines require the cleaning for multiple reasons. Maybe the best solution is an allowance for cleaning the line so we don't assume we have to clean all of it.”


Response:

The intent of the RFQ is to obtain an accurate condition assessment of the pipelines. Proposers may assume that spot or limited cleaning may be required to facilitate the CCTV inspection, but the RFQ does not currently assume that full cleaning of all lines will be necessary.

The Request for Quotations (RFQ) is modified as set forth in this Addendum.

The original RFQ Document remains in full force and effect, except as modified by this Addendum, which is hereby made part of the RFP. Respondents shall take this Addendum into consideration when preparing and submitting the Proposal.

Issued on: March 16, 2026



Lorena Matos Cádiz
Interim Deputy Executive Director